



材料暨工程實驗室-台中

試驗報告



報告編號：TB-24-06592

C-24-15926

頁數：1 OF 2

報告發行日期：113年10月21日

工程名稱：自測
承包商：-----
委託單位：安鑫建材有限公司
地址：新北市林口區文化三路一段372號15樓之2
供料廠商：-----
樣品名稱：超耐磨木地板-義大利(10 mm)
送驗人員：安鑫建材有限公司-范信安
收件日期：113年09月06日
試驗日期：113年09月06日~113年10月21日
備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

3.本樣品由SGS材料暨工程實驗室-台北(申請書號碼：HB-24-08060 C-24-30499，

收件日期：113年09月04日)轉送至本實驗室執行本報告所示之試驗項目。

試驗結果：

試驗項目	試驗結果	試驗方法
表面耐磨性-磨耗終點(轉)	17000	CNS 11367:1985
耐菸灼性(香菸直接燒灼法)	試片表面無不可清除之灼痕、褪色、龜裂及起泡等缺點	

註：1.耐磨試驗之片數為1片，研磨輪為AA180，附加於每一磨耗輪之載重為0.55 kg，

磨耗試驗機的旋轉盤的旋轉速度為60 r/min

2.試驗樣品厚度為10.1 mm

3.樣品描述：木地板

4.本實驗室執行試驗之地點同實驗室地址

----- 1 -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw
Member of SGS Group

TWE1539160

4004



材料暨工程實驗室-台中

試驗報告



報告編號: TB-24-06592

C-24-15926

頁數: 2 OF 2

報告發行日期: 113年10月21日

試驗結果:

試驗項目	試驗結果		試驗方法
防焰性	#火源加熱時間 (sec)	30	CNS 7614:1994 A法
	餘焰時間 (sec)	0	
	餘燼時間 (sec)	0	
	炭化長度 (cm)	5	

註: 1.樣品平均厚度 10.1 mm

2.試驗者: 葉家旋

3.測試面為表面(紋路面)

4.本試驗之樣品厚度不在試驗方法之適用範圍內(厚度須未滿5 mm), 故無法出具TAF標誌之報告

5.樣品描述: 木地板

6.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時,該規範值僅供參考,合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan /407271
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

TWE 1539159

台中市台中工業區14路9號

4004



材料暨工程實驗室-台中

試驗報告



報告編號：TB-24-06592

C-24-15926

頁數：1 OF 2

報告發行日期：113年10月21日

工程名稱：自測
承包商：-----
委託單位：安鑫建材有限公司
地址：新北市林口區文化三路一段372號15樓之2
供料廠商：-----
樣品名稱：超耐磨木地板-義大利(10 mm)
送驗人員：安鑫建材有限公司-范信安
收件日期：113年09月06日
試驗日期：113年09月06日~113年10月21日
備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

3.本樣品由SGS材料暨工程實驗室-台北(申請書號碼：HB-24-08060 C-24-30499，

收件日期：113年09月04日)轉送至本實驗室執行本報告所示之試驗項目。

試驗結果：

試驗項目	試驗結果	試驗方法
表面耐磨性-磨耗終點(轉)	17000	CNS 11367:1985
耐菸灼性(香菸直接燒灼法)	試片表面無不可清除之灼痕、褪色、龜裂及起泡等缺點	

註：1.耐磨試驗之片數為1片，研磨輪為AA180，附加於每一磨耗輪之載重為0.55 kg，

磨耗試驗機的旋轉盤的旋轉速度為60 r/min

2.試驗樣品厚度為10.1 mm

3.樣品描述：木地板

4.本實驗室執行試驗之地點同實驗室地址

----- 1 -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWE1539160

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

4004



材料暨工程實驗室-台中

試驗報告



報告編號: TB-24-06592

C-24-15926

頁數: 2 OF 2

報告發行日期: 113年10月21日

試驗結果:

試驗項目	試驗結果		試驗方法
防焰性	#火源加熱時間 (sec)	30	CNS 7614:1994 A法
	餘焰時間 (sec)	0	
	餘燼時間 (sec)	0	
	炭化長度 (cm)	5	

註: 1.樣品平均厚度 10.1 mm

2.試驗者: 葉家旋

3.測試面為表面(紋路面)

4.本試驗之樣品厚度不在試驗方法之適用範圍內(厚度須未滿5 mm), 故無法出具TAF標誌之報告

5.樣品描述: 木地板

6.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時,該規範值僅供參考,合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan /407271
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

TWE 1539159

台中市台中工業區14路9號

4004

材料暨工程實驗室-台中

試驗報告

報告編號：TB-24-03768
C-24-09254頁數：1 OF 2
報告發行日期：113年06月19日

標準檢驗局指定試驗室認可編號：SL3-JJ-C-0006

工程名稱：型式試驗

承包商：-----

委託單位：安鑫建材有限公司

供料廠商：-----

樣品名稱：複合木質地板

主要型式：型號(代號)：義大利系列，厚度：10 mm，甲醛釋出量標示符號：F3

送驗人員：安鑫建材有限公司-范信安

收件日期：113年05月27日

試驗日期：113年05月27日~113年06月19日

試驗方法：CNS 11342:103年10月

備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供


2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

=====

試驗結果：請見下一頁

-----1-----



本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

試驗報告



報告編號：TB-24-03768

C-24-09254

頁數：2 OF 2

報告發行日期：113年06月19日

試驗結果：

試驗項目	# 試驗規格	試驗結果	方法偵測極限 (MDL)
一、主要型式： 義大利系列 (10 mm, F3)	---	---	---
1. 甲醛釋出量	CNS 11342:103年10月	---	---
最大值 (mg/L)	2.1 以下	<0.2(0.1)	0.05
平均值 (mg/L)	1.5 以下	<0.2(0.1)	0.05
2. 標示檢查(非TAF認可項目，僅就 標示進行審查，未評定實質內容)	CNS 11342第7節標示項目	中文標示樣張符合	---

註： 1. 評定：符合(依據103年10月02日修訂之CNS 11342執行檢驗)

2. 本報告附件計有：

- (1) 型式試驗分類表2頁；(2) 規格一覽表、商品斷面圖及彩色照片(含厚度具尺規)共1頁；
- (3) 製程概要及中文標示樣張共1頁
3. 試驗結果若低於方法偵測極限值(MDL)之測定值以"N.D."表示；
若高於方法偵測極限值(MDL)，但低於定量極限值(QDL)時，以"<0.2"表示，
並括號註明其實測值，定量極限值(QDL)為 0.2 mg/L
4. N.D. = Not Detected / 未檢出
5. 本試驗報告甲醛釋出量試驗為TAF認證範圍，其餘則非
6. 樣品描述：複合木質地板
7. 本實驗室執行試驗之地點同實驗室地址

-----oOo-----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



化學實驗室-台北
Chemical Laboratory - Taipei



測試報告

報告編號: HTL24900005

報告日期: 2024/09/16

頁數: 1 of 3

安鑫建材有限公司
新北市林口區文化三路一段372號15樓之2

以下測試樣品係由申請廠商所提供及確認:

樣品名稱 : 超耐磨木地板-義大利(10mm)
委託單位 : 安鑫建材有限公司
委託單位地址 : 新北市林口區文化三路一段372號15樓之2
送樣單位 : 安鑫建材有限公司
送驗人員 : 安鑫建材有限公司(范信安)
備註 : 本樣品由SGS材料暨工程實驗室-台北(申請書號碼: HB-24-08058 C-24-30497, 收件日期: 113年 09月 04日), 轉送至本實驗室執行本報告所示之試驗項目。

=====

收件日 : 2024/09/09
測試期間 : 2024/09/09 to 2024/09/16
測試需求 : 依據客戶要求進行測試, 測試項目請參閱測試結果表格。
測試結果 : 請見下一頁。

Singh Hsiao
Singh Hsiao / Asst. Manager
Signed for and behalf of
SGS TAIWAN LTD.
Chemical Laboratory - Taipei



此報告是本公司依照背面所印之通用服務條款所簽發, 此條款可在本公司網站<http://www.sgs.com.tw/Terms-and-Conditions>閱覽, 凡電子文件之格式依<http://www.sgs.com.tw/Terms-and-Conditions>之電子文件期限與條件處理。請注意條款有關於責任、賠償之限制及管轄權的約定。任何持有此文件者, 請注意本公司製作之結果報告書將僅反映執行時所紀錄且於接受指示範圍內之事實。本公司僅對客戶負責, 此文件不妨礙當事人在交易上權利之行使或義務之免除。未經本公司事先書面同意, 此報告不可部份複製。任何未經授權的變更、偽造、或曲解本報告所顯示之內容, 皆為不合法, 違犯者可能遭受法律上最嚴厲之追訴。除非另有說明, 此報告結果僅對測試之樣品負責。

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No.25, Wu Chyuan 7th Rd., New Taipei Industrial Park, Wu Ku District, New Taipei City 248020, Taiwan / 248020 新北市五股區新北產業園區五權七路25號
t (886-2) 2299-3939 f (886-2) 2299-3237

www.sgs.com.tw

Member of SGS Group

TWE1727805
新北市五股區新北產業園區五權七路25號

3036

測試報告

報告編號: HTL24900005

報告日期: 2024/09/16

頁數: 2 of 3

安鑫建材有限公司
新北市林口區文化三路一段372號15樓之2

測試部位敘述

No.1 : 木紋貼皮及其下咖啡色板和貼皮

測試結果

測試項目	測試方法	單位	RL	結果 No.1
鄰苯二甲酸二(2-乙基己基)酯 (DEHP) (CAS No.117-81-7)	參考 CNS 15138-1 (民國101年) , 以氣 相層析儀質譜儀分析。	%	0.003	n.d.
鄰苯二甲酸二丁酯 (DBP) (CAS No.84-74-2)		%	0.003	n.d.
鄰苯二甲酸丁苯甲酯 (BBP) (CAS No.85-68-7)		%	0.003	n.d.
鄰苯二甲酸二異癸酯 (DIDP) (CAS No.26761-40-0, 68515-49-1)		%	0.003	n.d.
鄰苯二甲酸二異壬酯 (DINP) (CAS No.28553-12-0, 68515-48-0)		%	0.003	n.d.
鄰苯二甲酸二正辛酯 (DNOP) (CAS No.117-84-0)		%	0.003	n.d.
鄰苯二甲酸二甲酯 (DMP) (CAS No.131-11-3)		%	0.003	n.d.
鄰苯二甲酸二乙酯 (DEP) (CAS No.84-66-2)		%	0.003	n.d.

備註:

1. mg/kg = ppm ; 0.1% = 1000ppm
2. RL = 報告極限值
3. n.d. = Not Detected (未檢出) = 小於RL
4. 本報告不得分離或擷錄使用。

此報告是本公司依照背面所印之通用服務條款所簽發, 此條款可在本公司網站<http://www.sgs.com.tw/Terms-and-Conditions>閱覽, 凡電子文件之格式依<http://www.sgs.com.tw/Terms-and-Conditions>之電子文件期限與條件處理。請注意條款有關於責任、賠償之限制及管轄權的約定。任何持有此文件者, 請注意本公司製作之結果報告書將僅反映執行時所紀錄且於接受指示範圍內之事實。本公司僅對客戶負責, 此文件不妨礙當事人在交易上權利之行使或義務之免除。未經本公司事先書面同意, 此報告不可部份複製。任何未經授權的變更、偽造、或曲解本報告所顯示之內容, 皆為不合法, 違犯者可能遭受法律上最嚴厲之追訴。除非另有說明, 此報告結果僅對測試之樣品負責。

測試報告

報告編號: HTL24900005

報告日期: 2024/09/16

頁數: 3 of 3

安鑫建材有限公司
新北市林口區文化三路一段372號15樓之2


* 照片中如有箭頭標示，則表示為實際檢測之樣品/部位。 *

HTL24900005



正視圖

HTL24900005



背視圖

** 報告結尾 **

此報告是本公司依照背面所印之通用服務條款所簽發，此條款可在本公司網站<http://www.sgs.com.tw/Terms-and-Conditions>閱覽，凡電子文件之格式依<http://www.sgs.com.tw/Terms-and-Conditions>之電子文件期限與條件處理。請注意條款有關於責任、賠償之限制及管轄權的約定。任何持有此文件者，請注意本公司製作之結果報告書將僅反映執行時所紀錄且於接受指示範圍內之事實。本公司僅對客戶負責，此文件不妨礙當事人在交易上權利之行使或義務之免除。未經本公司事先書面同意，此報告不可部份複製。任何未經授權的變更、偽造、或曲解本報告所顯示之內容，皆為不合法，違犯者可能遭受法律上最嚴厲之追訴。除非另有說明，此報告結果僅對測試之樣品負責。

TWE1727807



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061

C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892



材料暨工程實驗室-台中

試驗報告



報告編號：TB-24-06592

C-24-15926

頁數：1 OF 2

報告發行日期：113年10月21日

工程名稱：自測
承包商：-----
委託單位：安鑫建材有限公司
地址：新北市林口區文化三路一段372號15樓之2
供料廠商：-----
樣品名稱：超耐磨木地板-義大利(10 mm)
送驗人員：安鑫建材有限公司-范信安
收件日期：113年09月06日
試驗日期：113年09月06日~113年10月21日
備註：1.以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2.除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

3.本樣品由SGS材料暨工程實驗室-台北(申請書號碼：HB-24-08060 C-24-30499，

收件日期：113年09月04日)轉送至本實驗室執行本報告所示之試驗項目。

試驗結果：

試驗項目	試驗結果	試驗方法
表面耐磨性-磨耗終點(轉)	17000	CNS 11367:1985
耐菸灼性(香菸直接燒灼法)	試片表面無不可清除之灼痕、褪色、龜裂及起泡等缺點	

註：1.耐磨試驗之片數為1片，研磨輪為AA180，附加於每一磨耗輪之載重為0.55 kg，

磨耗試驗機的旋轉盤的旋轉速度為60 r/min

2.試驗樣品厚度為10.1 mm

3.樣品描述：木地板

4.本實驗室執行試驗之地點同實驗室地址

----- 1 -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWE1539160

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan / 407271 台中市台中工業區14路9號
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

4004



材料暨工程實驗室-台中

試驗報告



報告編號: TB-24-06592

C-24-15926

頁數: 2 OF 2

報告發行日期: 113年10月21日

試驗結果:

試驗項目	試驗結果		試驗方法
防焰性	#火源加熱時間 (sec)	30	CNS 7614:1994 A法
	餘焰時間 (sec)	0	
	餘燼時間 (sec)	0	
	炭化長度 (cm)	5	

註: 1.樣品平均厚度 10.1 mm

2.試驗者: 葉家旋

3.測試面為表面(紋路面)

4.本試驗之樣品厚度不在試驗方法之適用範圍內(厚度須未滿5 mm), 故無法出具TAF標誌之報告

5.樣品描述: 木地板

6.本實驗室執行試驗之地點同實驗室地址

----- oOo -----

本報告若有提供規範值時,該規範值僅供參考,合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 9, 14th Rd. Taichung Industrial Park, Taichung 407271, Taiwan /407271
t (886-4) 2359-1515 f (886-4) 2359-2557

www.sgs.com.tw

Member of SGS Group

TWE 1539159

台中市台中工業區14路9號

4004



材料暨工程實驗室-台北

試驗報告



報告編號：HB-24-08059

C-24-30498

頁數：1 OF 1

報告發行日期：113 年 10 月 25 日

委託單位：安鑫建材有限公司
地址：新北市林口區文化三路一段 372 號 15 樓之 2
樣品名稱：超耐磨木地板-義大利(10mm)
送驗人員：安鑫建材有限公司(范信安)
收件日期：113 年 09 月 04 日
試驗日期：113 年 09 月 04 日~ 113 年 09 月 16 日
備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
2. 除非另有說明，此報告結果僅適用於收取之試驗件
未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	單位	RL	試驗結果
				No.1
溶出砷(As)(CAS No.7440-38-2)	參考 CNS 4797-2(民國 111 年)，以感應耦合電漿發射光譜儀(ICP-OES)分析	mg/kg	2.5	n.d.
溶出鋇(Ba)(CAS No.7440-39-3)		mg/kg	10	n.d.
溶出鎘(Cd)(CAS No.7440-43-9)		mg/kg	5	n.d.
溶出鉻(Cr)(CAS No.7440-47-3)		mg/kg	5	n.d.
溶出汞(Hg)(CAS No.7439-97-6)		mg/kg	5	n.d.
溶出鉛(Pb)(CAS No.7439-92-1)		mg/kg	5	n.d.
溶出銻(Sb)(CAS No.7440-36-0)		mg/kg	5	n.d.
溶出硒(Se)(CAS No.7782-49-2)		mg/kg	5	n.d.

備註：1. mg/kg = ppm; 0.1% = 1000ppm。

2. RL = 報告極限值。

3. n. d. = Not Detected(未檢出) = 小於 RL。

4. 樣品描述：木地板。

5. 本試驗委託 SGS 化學實驗室-台北(報告編號：HTY24900019)執行。

范信安

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

55, Wu Chyuan Road, New Taipei Industrial Park, Wu Ku District, New Taipei City 248016, Taiwan / 248016 新北市五股區新北產業園區五權路55號
t (886-2) 2298-3355 f (886-2) 2298-4219

www.sgs.com.tw

Member of SGS Group

TWD 7063277



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061

C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892

1030



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061
C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061
C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061
C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892



材料暨工程實驗室-台北



Testing Laboratory
2795

試驗報告



報告編號：HB-24-08061
C-24-30500

頁數：1 OF 1

報告發行日期：113年09月19日

委託單位：安鑫建材有限公司

地址：林口區文化三路一段372號15樓之2

樣品名稱：超耐磨木地板-義大利(10mm)

送驗人員：安鑫建材有限公司(范信安)

收件日期：113年09月04日

試驗日期：113年09月04日 ~ 113年09月16日

備註：1. 以上資料(會驗人員、試驗方法、試驗數量、收件日期及

試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅適用於收取之試驗件

未經本公司事先書面同意，此報告不可部分複製

試驗結果：

試驗項目	試驗方法	試驗結果
吸水厚度膨脹率(%)	CNS 11342 : 2014	0.2
密度(g/cm ³)	參考 CNS 2215 : 2017	0.90
耐衝擊性		無放射狀龜裂、破壞及化粧層之剝離，無明顯凹陷
耐酸性		表面無變色
耐鹼性		表面無變色
耐水性 B 試驗	參考 CNS 8058 : 2014	試片面板無割裂、鼓脹、剝離、顯著變色及光澤變化等現象

註：1. 本試驗報告吸水厚度膨脹率試驗為本實驗室 TAF 認證範圍，其餘則非。

2. 樣品描述：木地板。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

35, Wu Chyuan Road, (New Taipei Industrial Park) Wu Ku District, New Taipei City, Taiwan / 新北市五股區(新北產業園區)五權路35號
☎ (886-2) 2298-3355 ☎ (886-2) 2299-7857

www.sgs.tw

Member of SGS Group

TWB 9122892